

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N° 19-00289-1 L

And appendices of 0 page

MATERIAL presented by: Brand Management Group
1605 Main Street, Suit 503
Sarasota, FL34236
USA

TRADE NAME: H7304
HP light fabric

BRIEF DESCRIPTION: 100% polyester knitted fabric fireproofed by padding
Nominal surface weight: 216 g/m²
Nominal thickness: 0.40 mm
Colours: white

TEST REPORT: N° 19-00289 E1 – V1 on February 21st, 2019

TESTS: Electrical burner test
Flame persistence test
Dripping test.

CLASSIFICATION: **M 1**

CLASSIFICATION DURATION (article 5 of appendix 2) : limited 12 months from the date of the setting of the material in the regulated building, shielded from external weather conditions (material no washable and not suitable for dry cleaning)

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on October 17th, 2019



Sophie GUINAMAND
Engineer Tests and Trials